

Tatsfield Village Hall Fire Risk Assessment June 2020

INDEX

1 Fire Hazards

- A. Sources of Ignition and Action
- B. What could burn and Prevention
- C. Sources of Oxygen
- D. Arson attack

2 People at Risk

3 People at Greatest Risk

4 Specifically people using First floor rooms

5 Evaluation and Action

- A. Evaluation
- B. Action

6 Record, Plan and Inform

7 Review

8 Action Plan

Appendices

- A. Fire Notices
- B. Floor plans
- C. Occupancy

1 Fire Hazards

A	Sources of Ignition	Actions in place
	Gas Boiler	Annual gas inspection. Boiler located in an external brick room.
	Gas cooker	Annual gas inspection.
	Electrical Installation Condition	5-year electrical inspection (fixed wiring + 25% of accessories physically removed and replaced). Reported failures rectified.
	Chair Lift	Annual Inspection.
	Air Cooling Units	Annual Inspection.
	Portable Electrical Equipment including, but not limited to: Christmas Tree Extension Leads Fridge Freezer Heated Food Trolley Microwave Sound System Vacuum Cleaner Wine Chiller	PAT Tests Carried Out Annually. Test results, including items submitted by regular user groups, are retained by VHMC. Conditions of hire require that temporary or portable equipment is connected to socket outlets protected by one or more RCDs with adequate load current ratings and a 3-milliamp tripping current has a valid PAT certificate.
	Flammable Substance	Conditions of Hire Prohibit Flammable Substances.
	Naked Flames	
	Smoking: Inside the building	Prohibited. No smoking signs in place.

	Cigarette on outside wall of the building	Risk posed by cigarettes extinguished in bin attached to the wall assessed as being less significant than risk of cigarettes carelessly discarded if the bin is removed.
--	---	--

All Sources Currently Considered Low Risk

B	What Could Burn?	Prevention
	Curtains	Fire retardant to British Standards
	Rubbish	Conditions of hire stipulate rubbish to be removed from Hall after each hiring
	Group equipment	Stored in locked cupboards to reduce spread of fire. Pre-school items stored under stage and one electric light illuminates but wiring inspected and flammable items removed.
	Tables	Stored in closed cupboard/room to reduce spread of fire.
	Chairs and Screens	Stored in closed room to reduce spread of fire portable screens fire-proofed by manufacturer.
	Acoustic panels	Fireproofed on supply.
	Noticeboard	Complies with BS EN 13823:2002 & BS EN 11925-2.
	Dustbins	Outside and padlocked 6 feet away from premises.
	Paper: Files	Stored in locked cabinets in locked 1st floor room.
	Paper towels	Stored in locked cupboard on 1st floor.

All considered to be low risk except rubbish which considered medium if not removed

C	Sources of oxygen
	Natural ventilation through doors and windows. Air cooling unit.

Level of Risk low

D	Arson attack	Prevention
	Dustbins	Outside and padlocked 6 feet away from premises.
	Plastic toys used outside e.g. bikes	Stored in locked cupboard.
	Letter box: Door Outside box	Sealed. None - no reasonable alternative available.

Level of Risk to be Discussed

2 People at Risk

Regular users	Regular users' conditions of hire state that: The Hirer must ensure that group members are reminded at regular intervals of the directions set out in the Fire Notice.
Occasional Hirers	Occasional hirers' conditions of hire state that: The Fire Notice on the lobby noticeboard must be read aloud to all attendees at the beginning of the event.
Committee members	Committee members are all familiar with Fire Safety procedures.
Contractors	Before commencing work shall: <ol style="list-style-type: none"> 1) Read and comply to Tatsfield Village Hall Health and Safety Policy Document, displayed on foyer notice board, especially as regards lone working. 2) Read the Fire Notice. 3) Locate emergency exits, lighting controls and fire extinguishers. 4) Comply Understwith nd the No Smoking Policy. <p>Should it be essential that <u>when</u> substances hazardous to health or flammable substances are used when working we the <u>contractors will</u> hall ensure that they are handled and stored in accordance with COSHH and DSEAR requirements.</p>

3 People at Greatest Risk

Children	Little Acorns Pre School has its own Fire Safety Policy and undertakes its own Fire Safety risk assessment. There is a NO ENTRY notice hung at the bottom of the stairs. Little Acorns secures lobby and main hall exits with hooks. Ofsted have agreed risk assessment.
----------	--

	Conclusion that risk of children escaping outweighs risk of delayed exit.
Frail, elderly and disabled	Currently no regular bookings for old people's groups or organisations for people with disabilities. Attendees at occasional events sometimes include the elderly or people with impaired mobility but not in such numbers as to make escape within 2.5 minutes doubtful. Two double-door emergency exits are wheelchair accessible.
Lone workers	Anyone working alone <u>must comply to the</u> made aware of the Lone Worker Policy as detailed on page 11 of the Health & Safety Policy Document.

4 Specifically people using First floor rooms

Matters considered	<ol style="list-style-type: none"> 1) whether the smoke alarm could be heard throughout all the rooms. 2) whether there were any sources of ignition near the stairs. 3) the distance of travel from the area in question to the nearest exit. 4) whether doors leading to the escape route were closed. 5) the likely obstructiveness of the stair lift. 6) the difficulty of escape for anyone with impaired mobility.
It is considered that	<ol style="list-style-type: none"> 1) The smoke alarms <ol style="list-style-type: none"> i) are sited in the kitchen, the foyer and the landing ii) are regularly checked as part of assessment iii) sounders are audible upstairs 2) The possible sources of ignition are in i) the kitchen and ii) the lobby electrical cupboard. <ol style="list-style-type: none"> i) the risk of rapid spread of fire from the kitchen is reduced because: <ul style="list-style-type: none"> • the kitchen door conforms to current fire-retardant standards • conditions of hire require that the metal shutters between the kitchen and the main hall are closed at the end of each hiring • the doors leading to the main hall conform to fire standards applicable in 2000 ii) the fuse cabinet in the lobby <ul style="list-style-type: none"> • has a metal door which would resist the spread of fire • is out of the reach of children 3) In accordance with the Regulatory Reform (Fire Safety) Order 2005 the travel distance to the nearest emergency exit door is no more than 18 metres. 4) All first-floor rooms are locked when not in use <ol style="list-style-type: none"> i) the projection room is used rarely. Door closes automatically.

	<ul style="list-style-type: none"> ii) the middle room door is left open when in use iii) the back room is not in use at present iv) the toilets are rarely used. In common with all toilets the doors will be closed in use. This cannot be avoided. <p>5) When stationary, the lift would not impede rapid descent.</p> <p>6) Regrettably, the problem of quick escape for anyone with mobility difficulties is universal and usually insoluble. This risk is highlighted to Hirers.</p>
--	---

It was agreed that, on balance, the risk of being trapped on the first floor in the event of a fire was slight and not sufficient to preclude use of the rooms.

There is a Fire Action notice and a break glass alarm on the landing.

5 Evaluation and Action

A	Evaluation	<p>All risks of fire have been assessed as low with the control measures put in place.</p> <p>Risk to people has been reduced to low by the control measures put in place.</p> <p>Sources of fire are separated from ignitable materials.</p> <p>Ignitable materials are stored in locked cupboards to reduce the risk of arson.</p> <p>As rubbish is removed from premises by users there is a low risk of arson from bins.</p> <p>Letter box sealed, to remove opportunity of arson attack e.g. fireworks.</p>
----------	-------------------	--

B	Action	<p>Hire agreement indicates action in case of fire and familiarisation of equipment provided.</p> <p>It is statutory for Hirers to read fire notice to all attendees,</p> <p>Everybody made aware of health and safety policy statement as regards fire</p> <p>Smoke detectors to warn of outbreak of fire</p> <p>Alarm points throughout building</p> <p>Alarm bells to inform of fire audible in all areas</p> <p>Alarm system tested as per schedule</p> <p>Responsibility of nominated hirer to evacuate hall</p> <p>Responsibility of nominated hirer to call fire service and advise hall committee member</p>
----------	---------------	--

	<p>Emergency lighting to assist exit</p> <p>Emergency lighting tested as per schedule</p> <p>Fire extinguishers throughout building, to assist exit and control small fire if safe to do so.</p> <p>Fire blanket in kitchen to assist exit and control small fire if safe to do so.</p> <p>Fire extinguishers tested as per schedule.</p> <p>Emergency exits unobstructed inside and out and unlocked to facilitate emergency evacuation</p> <p>Emergency exits easily opened and exit routes indicated, tested as per schedule</p> <p>Evacuation to safe distance as per Health and Safety Policy Statement.</p>
--	---

6 Record, Plan and Inform

Record	<p>Copies of the current Fire Safety Risk Assessment including updates will be retained by the Village Hall Management Committee.</p>
Plan	<p>The Fire Action notices and plans indicating emergency exits, location of extinguishers and smoke alarms form part of this Fire Safety Risk Assessment.</p> <p>The area of the main hall is 180sq metres. Conditions of hire allow a maximum number, including performers and staff at any event to 180 for theatre or cinema seating arrangement and 150 for cabaret style, music and dancing or sport. This conforms with recommended occupant capacity figures.</p> <p>All emergency exits open outwards. The widths are as follows:</p> <ul style="list-style-type: none"> lobby 130cm main hall side 140cm stage 150cm green room stairs 68cm <p>Ignoring the widest exit and the green room stairs exit, it is calculated that 180 occupants could be evacuated within 2.5 minutes.</p> <p>No policy in place in respect of sleepovers (none has yet occurred) <u>Sleepovers are currently not permitted in the hall for hirers.</u></p> <p>Health and Safety Policy statement sets out time scale for maintenance of:</p> <ul style="list-style-type: none"> fire fighting equipment

	<p>fire alarm system emergency lighting emergency exits and emergency exit signs</p>
Inform, Instruct and Train	<p>Fire notices are prominently displayed in the lobby. A notice is displayed on the first-floor landing.</p> <p>Regular users' conditions of hire state that: The Hirer must ensure that group members are reminded, at regular intervals of the directions set out in the Fire Notice.</p> <p>Occasional hirers' conditions of hire state that: The Fire Notice on the lobby noticeboard must be read aloud to all attendees at the beginning of the event.</p> <p>Trustees and regular user groups invited to attend training and information sessions organised by SCA and TVSC.</p> <p>Organisers of Fairs and Horticultural Shows are alerted to Fire Safety requirements.</p>

7 Review

The Village Hall Fire Safety Risk Assessment is reviewed annually.

Additionally, the Village Hall Fire Safety Risk Assessment will be immediately reviewed:

- in the event of changes to the building or work practices
- in the event of fire or near miss
- should any possible or potential risk be identified and reported by any group or individual.

8 Action Plan

- Check location of Accident Book
- Contacted Little Acorns regarding their policy documents. (awaiting response)
- Create policy for sleepovers

APPENDIX A

FIRE NOTICES

Lobby noticeboard

IN CASE OF EMERGENCY

LOCATION OF:

BREAK GLASS ALARMS

on the walls: to the left of the lobby entrance doors
to the left of the emergency exit doors at the foot of the stage
stairs
to the left of the exit on the green room stairs
on the first floor facing the stairs

EMERGENCY EXITS

doors: the main entrance to the lobby
at the foot of the stage stairs
at the back of the stage
on the green room stairs landing

FIRE EXTINGUISHERS: WATER

on the walls: to the left of the lobby entrance doors
to the left of the emergency exit doors at the foot of the stage
stairs
to the right of the emergency exit doors on the stage
at the foot of the green room stairs
on the upstairs landing

CO2

on the walls: to the left of the lobby entrance doors
to the left of the emergency exit doors at the foot of the stage
stairs to the right of the emergency exit doors on the stage
in the kitchen, to the right of the hand-washing sink
in the green room cupboard
on the upstairs landing

FIRE BLANKET:

In the kitchen on the wall opposite the window

TELEPHONE

On the wall to the left of the chair storeroom available for free 999 calls
only

Public telephone on the other side of the green, outside the Bakery

MAINS ELECTRICITY SWITCH

red switch in the grey fuse box in the top right-hand cupboard to the left of
the main entrance

GAS MASTER TAP

in the brick-built control box outside the Hall by the kitchen window. The
key is kept on a
hook above the hat shelf in the left-hand corner of the cloakroom.

WATER STOP-COCK

under the left-hand cupboard under the sink

FIRST AID BOX

in the drawer to the right of the cooker

ACCIDENT RECORD BOOK

in the first aid box

Lobby noticeboard

IN THE EVENT OF FIRE

Activate the nearest alarm
Telephone the fire brigade (999) from the phone on the wall to the left of the toilets if safe to do so
or use a mobile phone or the public box outside the Bakery

If the fire is *small*, attempt to extinguish using the *appropriate* extinguisher

Leave the Hall by the nearest exit

Assemble on the green in front of The Ship

Do not return to the Hall until authorised

The person in charge should ensure that:

all occupants are assembled on the green
clear access is maintained for emergency services
someone is available to liaise with the emergency services

First floor landing and Green Room stairs



IN CASE OF A FIRE

Fire Alarm The system works automatically via smoke alarms in various locations or by break glass units.

Fire Assembly Point: Green triangle outside The Ship Public House

On Discovering a Fire: Activate the alarm if the automatic system has not operated
Dial 999 and notify the Emergency Services
Attempt to extinguish any small fire using the equipment provided but do not take any unnecessary risks

Action When The Alarm Has Been Activated: If you have attempted to extinguish the fire but have failed to do so promptly do not continue further and leave the premises

Immediately leave the premises and assemble at the Fire Assembly Point

Evacuate the building even if the alarm stops

Do not collect personal belongings

Do not run, remain calm & bring others with you as you leave the premises

Do not re-enter the building until instructed to do so by the person in charge

Emergency Evacuation Procedure – Person in Charge / Hirer / Contractor

Person in Charge / Hirer / Contractor On Discovering a Fire or Being Made Aware of a Fire: Activate the alarm if the automatic system has not operated

Ensure that the Emergency Services are informed immediately, however small the incident

Action When The Alarm Has Been Activated:

Ensure that all occupants evacuate the premises in a calm manner, marshalling on the Green triangle opposite the Ship Public House

Ensure that no attempt is made to remove any cars from the car park

Liaise with the emergency services upon their arrival and until they depart

Ensure clear access is maintained for the emergency services.


APPENDIX B

LOCATION OF FIRE SAFETY EQUIPMENT


Floor Plans

Location of extinguishers,
Emergency exits
smoke alarms )
break glass alarms )

Ground floor



First floor





APPENDIX C

Regular term time occupancy

Mon	07.00-15.30	Little Acorns ¹	15.45-17.00	Dance First ¹	17.00-19.00	Dance First	19.30-22.00	Art Group
Tues	07.00-15.15	Little Acorns ¹	15.30-17.00	Dance First ¹	17.00-19.00	Dance First	19.30-23.30	Badminton
Wed	07.00-12.30	Little Acorns ¹	13.30-16.15	Shrt Mat Bowls ²	17.45-18.45	Private ballet	20.00-21.30	Yoga class
Thurs	07.00-15.30	Little Acorns ¹	16.00-17.00	Right Start ³	18.15-19.15	Vets' Football	19.30-22.30	Table Tennis
Fri	07.00-12.30	Little Acorns ¹	13.30-16.15	Shrt Mat Bowls ²			18.15-23.00	Badminton
Sat	09.30-11.00 monthly	Advanced M'cyclists						
Sun			14.00-17.00 monthly	NDS rehearsal ⁴	17.00-18.00 fortnightly	Tai Kwondo private prtce ⁵		

occasional bookings - average per month

3 x children's private parties ¹
 1 x private parties ⁶
 2 x events organised by village organisations

most at risk

- ¹ young children
- ² elderly but active and not frail
- ³ puppies in training (owners would not leave)
- ⁴ valuable instruments (owners unlikely to leave)
- ⁵ lone occupancy

6 likely alcohol consumption